

Barcol-Air Netherlands casing leakage test sheet

According to standard NEN-EN 15727-2010

Test setup		
Date	24-3-2021	Reference nr. LM-21-0004
Exp. Date	24-3-2024	Tested by TK
Place	Barcol-Air	Witness by MBs
Air temperature	20 [°C]	
Atmospheric pressure	1013 [hPa]	

Contact information	
Tel	+31 (0)299 689 300
Email	barcol-air@hcgroep.com
Website	www.barcol-air.nl



Model (Name/Type): **rectangular airflow measuring station AEROO0B-0250-0200**

Result: **Class C**

Product specifications		
Productcode	AEROO0B	
Model	250x200	
Case Width	0,250	[m]
Case Height	0,200	[m]
Case Diameter		[m]
Case Length	0,350	[m]
Real Duct surface	0,315	[m ²]
Virtual Duct surface	0,900	[m ²]
Note:	When Case Length <1m; 1m is used in calculations as specified by LUKA.	


Measurement specifications		
Pressure time	60 seconds	
Pressure controller	PR-41X/20mbar/81955.50	
Airflow meter(s)	Low Flow	F-111B-20K-RAD-00-V
	High Flow	F-112AC-M20-RAD-55-V
Rated Accuracy	Pressure Ctrl	± 0,05%Rd + 0,093%FS
	Low Flow	± 0,5%Rd + 0,1%FS
	High Flow	± 0,5%Rd + 0,1%FS
	Pressure Ctrl	21-2-2020
Date calibrated	Low Flow	8-10-2020
	High Flow	9-10-2020

Leakage is measured in normal liters (= 1 liter at 0°C and 101325 pa)

NEN-EN 15727-2010	
Max. Leakagefactor [l _v /s/m ²]	
Class A	0,027
Class B	0,009
Class C	0,003
Class D	0,001
$\Phi L = f \times P_s^{0,65}$	
ΦL Leakage [l _v /s/m ²]	
f = Leakagefactor	
P _s = Static Pressure	

Measurements and calculations					
Reading	Measure instrument	Static pressure [Pa]	Measured air leakage rate [l _v /s]	Corrected air leakage rate 20°C [l _v /s]	Product tightness factor [l _v /s/m ²]
1		400	0,091	0,091	0,101
2		1000	0,178	0,178	0,198
3		2000	0,287	0,287	0,319
4					
5					

LUKA standards				
Class A	Class B	Class C	Class D	Estimated class
[l _v /s/m ²]	[l _v /s/m ²]	[l _v /s/m ²]	[l _v /s/m ²]	
1,33	0,44	0,15	0,05	Class C
2,41	0,80	0,27	0,09	Class C
3,78	1,26	0,42	0,14	Class C
0,00	0,00	0,00	0,00	Class C
0,00	0,00	0,00	0,00	Class C



Other results	
Visual deformation	Negative
Pressure [Pa]	2000

*As the tested model is the smallest model of this product range, the same classification result (or better) is valid for all larger models.

Approved and certified by
TÜVRheinland[®]
 Precisely Right.
 Certificate nr. P-97/52-45

Calibration certifications nr.
 Low Flow BHTG19/5615748
 High Flow BHTG22/5617022
 Pressure ctrl not specified